

ORDINANCE NO. 2788

AN ORDINANCE TO AMEND ORDINANCE NO. 2413, PROVIDING FOR THE REGULATION OF THE INSTALLATION, MAINTENANCE, REPAIR AND ALTERATION OF ELECTRIC SYSTEMS; AMENDING SECTION 2 THEREOF AND DECLARING AN EMERGENCY.

THE PEOPLE OF THE CITY OF ALBANY DO ORDAIN AS FOLLOWS:

Section 1: Section 2 of Ordinance No. 2413, is amended to read as follows:

"Section 2: ADOPTION OF THE NATIONAL ELECTRICAL CODE. The National Electrical Code, 1956 Revision as promulgated by the National Board of Fire Underwriters and American Standards Association is hereby adopted and made a part of this Ordinance as if it were herein set forth in full. Provided, however, that all wiring hereinafter installed in a new structure or repairs or replacements installed in an existing structure within the boundaries of Fire District No. 1 as established or as hereafter changed by proper authority shall be installed in rigid metal conduit or multi-outlet assemblies and provided further that all wiring hereinafter installed in commercial buildings or in public or semi-public buildings such as schools, churches, lodges or buildings where the public will assemble or patronize within any part of Albany shall be installed in rigid metal conduit or multi-outlet assemblies. Provided that flexible metal conduit may be used in making connections to motors or other appliances, and in other installations wherein, in the opinion of the building and electrical inspector, rigid connections would not be practical and where the length of said flexible conduit shall not exceed five (5) feet in length."

Section 2: In as much as this Ordinance is necessary for the immediate preservation of the public health, peace and safety of the citizens of the City of Albany, an emergency is hereby declared to exist and it will become effective upon its passage by the Council and approval by the Mayor.

Passed by the Council: June 9, 1958

Approved by the Mayor: June 9, 1958

W R Fitzpatrick
Mayor

Effective Date: June 9, 1958

ATTEST:

Arthur P. Bliven
Recorder