

RESOLUTION NO. 3624

A RESOLUTION AMENDING THE CITY OF ALBANY'S LOCAL LIMITS FOR THE DISCHARGE OF POLLUTANTS OF CONCERN TO THE PUBLICLY OWNED TREATMENT SYSTEM.

WHEREAS, Federal regulations 40 CFR Part 403.5 require Publicly Owned Treatment Works (POTWs) to develop local limits for the discharge of pollutants of concern to the wastewater treatment system; and


WHEREAS, the State Department of Environmental Quality (DEQ) is designated as the Approval Authority to regulate POTWs in Oregon and has required the City of Albany to develop and revise local limits for the discharge of pollutants of concern to the wastewater treatment system; and

WHEREAS, the Albany Municipal Code Chapter 10.01.040 requires the development and revision of standards for specific restricted substances; and

WHEREAS, City staff has developed revised local limits (Attachment A). Using methods provided by DEQ, the City has fulfilled public notice requirements through notice in the *Albany Democrat-Herald*. DEQ has provided a letter stating their intent to approve the revised local limits, and the Environmental Protection Agency's Region 10 office has been provided with proper notification by DEQ.

NOW, THEREFORE, BE IT RESOLVED by the City Council of Albany that the revised local limits be adopted and in force from the date of this resolution.

DATED THIS 10TH DAY OF APRIL 1996.



Mayor

ATTEST:



City Recorder

Q:PROG\MCLRES.MF

RESOLUTION NO. 3624

ATTACHMENT A

CITY OF ALBANY LOCAL LIMITS

	<u>Limit, mg/L</u>
Arsenic	1.0
Cadmium	0.6
Chromium	2.8
Copper	3.4
Cyanide	1.2
Lead	0.7
Mercury	0.08
Molybdenum	4.0
Nickel	1.6
Selenium	3.0
Silver	1.1
Zinc	2.6
Oil and Grease	300

November 1995 revision. Albany local limits were calculated using wastewater treatment plant and collection system data, under methods recommended by the Oregon Department of Environmental Quality.