



**NOTES:**

1. MINIMUM CLEARANCE BETWEEN PIPES SHALL BE 12" UNLESS APPROVED BY THE CITY ENGINEER.
2. INSTALL UNDERGROUND UTILITY SUPPORT WHEN CLEARANCE BETWEEN PIPES IS LESS THAN 12".
3. CONTROLLED DENSITY FILL SHALL HAVE AN ULTIMATE COMPRESSIVE STRENGTH OF 50 PSI MINIMUM TO 200 PSI MAXIMUM. SEE SPECIAL PROVISIONS.

CITY OF ALBANY, OREGON  
PUBLIC WORKS DEPARTMENT

UNDERGROUND  
UTILITY SUPPORT

NO SCALE

FEBRUARY 2024

NO. 211